



# Certificate of Compliance

**Certificate:** 70019740

**Master Contract:** 154942

**Project:** 70027753

**Date Issued:** April 17, 2015

**Issued to:** Peter Paul Electronics Company

**Incorporated**  
**480 John Downey Dr.**  
**New Britain, CT 06050**  
**USA**  
**Attention: Ernie Affricano**

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



*Richard Clark*

**Issued by:** Richard Clark

## **PRODUCTS**

**CLASS 3371 03** - VALVES (GAS) - Automatic - For Gas Appliances

**CLASS 3371 83** - VALVES (GAS) - Automatic-For Gas Appliances-Certified to U.S. Standards

Series 80 2 Way Normally Closed Valve

E829B11DCCP-SC

E829B11RCCP-SC

E829B11OCCP-SC

E829B33DCCP-SC

E829B33RCCP-SC

E829B33OCCP-SC



**Certificate:** 70019740

**Master Contract:** 154942

**Project:** 70027753

**Date Issued:** April 17, 2015

---

E829BNDCCP-SC

E829BADCCP-SC

E829BCDCCP-SC

E829BEDCCP-SC

12 VDC, 24 VDC, 120 VAC

60 PSI Maximum Pressure Rating.

Ambient and Media Temperature Range -40°C to 65°C

C/I Rated

**APPLICABLE REQUIREMENTS**

ANSI Z21.21-2012 / CSA 6.5-2012 Automatic Valves for Gas Appliances